

Certificate of Compliance

Certificate Number:

UL-US-2326223-2

Report Reference:

EX28742-20230309

Issue Date:

2024-09-18

Issued to:

Reacton Fire Suppression LTD
14 Baynes Place
Waterhouse Business Park Chelmsford CM1 2QX
United Kingdom

This certificate confirms that representative samples of:

GAQF - Clean-agent Extinguishing System Units

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

ANSI/CAN/UL/ULC 2166, 3rd Ed, Issue Date: 2017-5-10, Revision Date: 2021-12-8

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



A handwritten signature in black ink, appearing to read 'David Piecuch'.

David Piecuch
UL Mark Certification Program Owner

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2326223-2
Report reference EX28742-20230309
Date 2024-09-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
CTX Indirect, Reacton1230 Fire Clean Agent pre-engineered extinguishing system units, 25 bar	Pre-Engineered, Halocarbon

Clean Agent Extinguishing System Units		Value
Extinguishing Agent (ASHRAE Designation)		FK-5-1-12
Manuals and Bulletins		
Part No.	Description	Date/Rev
USM0013	Design, Installation and Maintenance Manual EU Market	Rev. C, January 01, 2024
USM0014	Design, Installation and Maintenance Manual US Market	Rev. C, January 01, 2024
System Unit Information		
Operating Pressure at Temperature	Minimum Operating Temperature	Maximum Operating Temperature
25 bar @ 20C	-20 C (-4 F)	60 C (140 F)



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.